

SAFE DRINKING WAND SANITARY CERTIFICATE

Appendix-III

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

No. 06

Date: 29/01/2025


It is certified that an inspection team headed by Shiv Kumar Dinkar, Assistant Engineer, (Name of Officers with designation) from Drinking Water and Sanitation Sub Division, Jamshedpur (Name of Department/Office) inspected the Holy Cross School, Behind Cheshire Home Patel Bagan, Sundernagar, Jamshedpur (Name and Address of the School) on 29/01/25 and found that the Holy Cross School (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintain the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Central / State/ U.T Govt.

The above valid for a period of one year.

Signature with Seal:

Name

Designation:


29/01/25
Assistant Engineer
D.W. & S. Sub Div
Jamshedpur
Shiv Kumar Dinkar
Assistant Engineer

To,
Holy Cross School
Behind Cheshire Home, Patel Bagan
Sundernagar, Jamshedpur

Asst.
Manager
Holy Cross School
Sundernagar Patel Bagan


Principal
Holy Cross School
Patel Bagan Sunder Nagar
Jamshedpur-832107



District Level Water Testing Laboratory
Office of the Executive Engineer (DW&SD)
Near Adityapur Thana, Jamshedpur-831013
Email: dlwtl.jamshedpur@gmail.com

Report No:	JSR/2025/07	Memo no:	21/18-01-2025
Issue To/ Name and Address of customer:	Holy Cross School Patel Bagan, Sundar Nagar, JSR-832107	Sample code:	250117SWJP07
Sample Type:	Drinking water	Sample collected by	School Staff
Sample Received on:	17/01/2025	Sample Description:	Supply Water
Test start on :	17/01/2025	Date completion on:	18/01/2025
ULR:			

Test Result

Sl. No.	Tested Parameter	Unit	Results	Method	Specification as per IS – 10500-2012 (Second Revision)	
					Acceptable Limit	Permissible Limit (Absence of Alternate source)
1	pH, at 25°C	-	6.64	APHA 24th Ed.2023-4500-H ⁺ B, (Electrometric method)	6.5 – 8.5	No relaxation
2	Turbidity	NTU max	0.08	APHA 24 th Ed.2023-2130 B, (Nephelometric method)	1	5
3	Alkalinity as CaCO ₃	mg/L max	144	APHA 24 th Ed.2023-2320 B, (Titration method)	200	600
4	Calcium as (Ca)	mg/L max	41.6	APHA 23 rd Ed.2017-3500 Ca B, (EDTA Titration method)	75	200
5	Magnesium as Mg	mg/L max	13.44	APHA 24 th Ed.2023-3500-Mg B, (Calculation method)	30	100
6	Hardness as CaCO ₃	mg/L max	160	APHA 24 th Ed.2023-2340 C, (EDTA Titration method)	200	600
7	Fluoride as (F)	mg/L max	0.68	APHA 24 th Ed.2023-4500 F ⁻ C, (Ion selective electrode method)	1.0	1.50
8	Total Dissolved Solids at 180°C	mg/L max	254	APHA 24 th Ed.2023-2540 C, Total Dissolved Solids Dried at 180°C	500	2000
9	Chloride (cl)	mg/L max	25.80	APHA 24 th Ed.2023-4500 Cl B, (Argentometric method)	250	1000
10	Colour	Hazen	01	IS:3025, (Part-4)	5	15
11	Taste	-	Agreeable	IS:3025, (Part-5)	Agreeable	-
12	Odour	-	Agreeable	IS: 3025, (Part-7)	Agreeable	-

Remarks:- This result is according to BIS limit.

Specific contractual notes: -

- ♦ The results listed refer only to the tested sample and applicable parameter.
- ♦ This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- ♦ This report can not be reproduced, except when in full, without the written permission of the Lab In-charge.
- ♦ Tested Sample shall be retained up to Seven Days from the date of issue of the certificate.
- ♦ The liability of the laboratory is limited to the invoiced amount.
- ♦ All disputes are subjected to the Jamshedpur Jurisdiction.
- ♦ NOTE:- BDL=Below Detection Limit / DL=Detection Limit.
- ♦ Sample is not drawn by laboratories.

[Signature]
Principal

Holy Cross School
Patel Bagan, Sundar Nagar
Jamshedpur-832107

[Signature]
18/01/25

Supriya Kumari
Authorised Signatory
(Quality Manager)

Reviewed by : Phulchand Mahato
[Signature]
Manager

Holy Cross School

District Level Water Testing Laboratory
Jamshedpur



District Level Water Testing Laboratory
Office of the Executive Engineer (DW&SD)
Near Adityapur Thana, Jamshedpur-831013
Email: dlwtl.jamshedpur@gmail.com

Report No.	JSR/2025/07	Sample code	250117SWJP07
Name and Address of Customer	Holy Cross School Patel Bagan, Sundar Nagar, JSR-832107	Memo no:	
			21/18-01-2025
Sample Type	Drinking water	Sample Collected by:	School Staff
Sample receipt on	17/01/2025	Sample description:	Supply Water
Date of start Analysis	17/01/2025	Date of completion	18/01/2025
ULR:			

Bacteriological Test Report

S.No	Parameter	Test Method	Unit	Result	Remarks
01	Total Coliform	APHA 9222B 24th Edition 2023	Cfu/100mL	Absent	Shall not be detectable in any 100 ml sample
02	Fecal Coliform	APHA 9222D 24th Edition 2023	Cfu/100mL	Absent	Shall not be detectable in any 100 ml sample

Specific contractual notes: -

- ♦ The results listed refer only to the tested sample and applicable parameter.
- ♦ This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- ♦ This report can not be reproduced, except when in full, without the written permission of the Lab In-charge
- ♦ Tested Sample shall be retained up to Seven Days from the date of issue of the certificate.
- ♦ The liability of the laboratory is limited to the invoiced amount.
- ♦ All disputes are subjected to the Jamshedpur Jurisdiction.

Tested by: Manisha

Supriya Kumari
18/01/25

Supriya Kumari
Authorised Signatory
(Quality Manager)

Quality Manager

District Level Water Testing Laboratory
D.W. & S. Division, Jamshedpur

District Level Water Testing Laboratory
Jamshedpur, Jharkhand

.....End of the Report.....

Asyt
Manager
Holy Cross School
Sundarnagar Patel Bagan

Principal
Principal
Holy Cross School
Patel Bagan Sunder Nagar
Jamshedpur-832107